

**RESOLUTION NO. 255-2, SERIES 1985**  
**April 8, 1985 - 255<sup>th</sup> Council Meeting**  
**MAGAT OPERATION RULE CURVE**

RESOLVED, AS IT IS HEREBY RESOLVED, to adopt the operation rule curve of the Magat Reservoir in order to optimize the power and energy generation capability of the Magat Power Plant.

RESOLVED FURTHER, that the following criteria be observed in conjunction with the rule curve:

- a) The water surface elevations of the reservoir at any given time should not be allowed to go below the rule curve.
- b) As long as the water surface elevation is above the rule curve, additional water releases for power generation should be allowed in addition to release requirements for irrigation provided, that the resulting reservoir level will not fall below the rule curve.